Energy performance certificate (EPC)

4 Leathermarket Street LONDON SE1 3HN Energy rating

Valid until: 20 April 2027

Certificate number: 0040-5975-0373-3690-7090

Property type

B1 Offices and Workshop businesses

Total floor area

299 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is C.

Under 0 A+

Net zero CO2

0.25 A

26-50 B

51-75 C 61 C

76-100 D

101-125 E

126-150 F

Over 150 G

Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If newly built	25 A
If typical of the existing stock	74 C

Breakdown of this property's energy performance

Main heating fuel	Natural Gas
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO2/m2 per year)	34.51
Primary energy use (kWh/m2 per year)	199

Recommendation report

Guidance on improving the energy performance of this property can be found in the <u>recommendation</u> <u>report (/energy-certificate/9539-4094-0737-0700-6501)</u>.

Who to contact about this certificate

Contacting the assessor

Date of assessment

Date of certificate

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name Ori Reiss

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Stroma Certification Ltd
Assessor's ID	STRO003801
Telephone	0330 124 9660
Email	certification@stroma.com
About this assessment	
Employer	EPC Assure Ltd
Employer address	20-22 Wenlock Road London N1 7GU
Assessor's declaration	The assessor is not related to the owner of the
	property.

6 April 2017

21 April 2017